1 2

## 4007 Determination of Gas Permeance of packaging materials and containers for pharmaceutical use

This method, which is applicable to determining the gas permeance of the 3 4 packaging materials or containers for pharmaceutical use, consists of differential-pressure method and coulometric method. The differential-pressure 5 method is only suitable for testing of the films or sheeting, and the coulometric 6 7 method is only suitable for determining the oxygen gas permeance.

8 Gas transmission rate (GTR) is defined as the volume of the steady-state 9 transmission of a gas through a unit area of the test specimen or a container in unit 10 time, under specified conditions of temperature and humidity. It is generally 11 expressed as the volume at a standard temperature and under standard atmospheric 12 pressure, in the unit of  $cm^3/(m^2\cdot 24h)$  for films or sheeting, and in the unit of  $cm^3/(m^2\cdot 24h)$  for films or sheeting, and in the unit of  $cm^3/(m^2\cdot 24h)$  for containers.

Gas permeance is defined as the volume of the steady-state transmission of a gas, under unit pressure difference, through a unit area of the test specimen or a container in unit time, under specified conditions of temperature and humidity. It is generally expressed as the volume at a standard temperature and under standard atmospheric pressure, in the unit of  $cm^3/(m^2\cdot 24h\cdot 0.1Mpa)$  for film or sheeting, and in the unit of  $cm^3/(container\cdot 24h\cdot 0.1Mpa)$  for containers.

Gas permeability coefficient is defined as the volume of the steady-state transmission of a gas, under unit pressure difference, through the test specimen of unit thickness, per unit area and unit time, under specified conditions of temperature and humidity. It is generally expressed as the volume at a standard temperature and under standard atmospheric pressure, in the unit of  $cm^3 \cdot cm/(m^2 \cdot 24h \cdot 0.1Mpa)$ .

Test environment should be at a temperature of  $23^{\circ}C \pm 2^{\circ}C$  and a relative humidity of  $50\% \pm 5\%$ .

27

## Method1 Differential-pressure method

The high-pressure chamber filled with about 0.1MPa of the test gas and the 28 low-pressure chamber of known volume are separated by the film or sheeting for 29 pharmaceutical use. After being sealed by the test specimen, the low-pressure 30 chamber is evacuated of all air by a vacuum pump. Then the pressure increment ( $\Delta P$ ) 31 of the low-pressure chamber is measured by a manometer to determine the amount of 32 33 gas passing through the test specimen from the high-pressure chamber to the 34 low-pressure chamber as a function of time, but the initial period during which the gas transmission rate changes with the time should be excluded. 35

Apparatus and materials An apparatus for determining gas permeance by
 differential-pressure method mainly consists of the following parts:

**Transmission cell** The cell consists of an upper part and a lower part. When the test specimen is mounted, the upper part equipped with a gas inlet tube is the high-pressure chamber for containing the test gas, and the lower part is the 41 low-pressure chamber for containing the permeated gas and determining the42 difference in pressure before and after the gas permeation.

43 **Manometric device** The high-pressure chamber and the low-pressure chamber 44 should be respectively equipped with a manometer. The manometer in the 45 high-pressure chamber should be with a minimum sensitivity of 100 Pa, and that in 46 the low-pressure chamber should be with a minimum sensitivity of 5 Pa.

47 Vacuum pump The pump should be capable of producing a pressure lower than
48 10 Pa in the lower-pressure chamber.

49 **Test gas** The purity of the test gas should not be less than 99.5%.

Procedure Choose three pieces of the test specimens, which should be of 50 51 uniform thickness and suitable size, and should be free from wrinkles, creases, pinholes and other defects. Mark the side of each specimen facing the test gas, and 52 condition the specimens at 23°C±2°C in a desiccator for more than 48 hours. Measure 53 the thickness at least five points of each specimen to the nearest 0.001 mm with a 54 55 suitable gage, and take the arithmetic mean of the measurements. Mount the specimen, and carry out the test. Perform a pre-permeation experiment for 10 minutes to reject 56 the nonlinear phase in the initial period of the test, and continue the test until the 57 steady permeation to be attained as the changes of pressure difference in the equal 58 intervals of timeremain constant. 59

60 The gas permeance  $(P_g)$  could be calculated according to the following equation:

61 
$$P_g = \frac{\Delta P}{\Delta t} \times \frac{V}{S} \times \frac{T_0}{P_0 T} \times \frac{24}{(P_1 - P_2)}$$

- 62 Where:  $P_g$  is the gas permeance of the test specimen, cm<sup>3</sup>/ (m<sup>2</sup>·24h·0.1Mpa);
- 63  $\Delta P/\Delta t$  is the arithmetic average of pressure changes of the low-pressure 64 chamber per unit time, under steady permeation, Pa/h;
- V is the volume of the low-pressure chamber,  $cm^3$ ;
- 66 S is thetestarea of the test specimen,  $m^2$ ;
- 67 T is the test temperature, K;
- $P_1$ -P<sub>2</sub> is the pressure difference between the two sides of the specimen, Pa;
- 69  $T_0$  is the standard temperature (273.15K);
- 70  $P_0$  is the standard atmospheric pressure (0.1Mpa).

The coefficient of gas permeability  $(P_g')$  could be calculated according to the following equation:

73 
$$P'_{g} = \frac{\Delta P}{\Delta t} \times \frac{V}{S} \times \frac{T_{0}}{P_{0}T} \times \frac{24 \times D}{(P_{1} - P_{2})} = P_{g} \times D$$

- 74 Where  $P'_{g}$  is the coefficient of gas permeability of the test specimen, cm<sup>3</sup>·cm/ 75 (m<sup>2</sup>·24h·0.1Mpa);
- 76  $\Delta P/\Delta t$  is the arithmetic average of pressure changes of the low-pressure 77 chamber per unit time, under steady permeation, Pa/h;
- 78 T is the test temperature, K;
- 79 D is the thickness of the test specimen, cm.

Take the arithmetic mean of three specimens as the test result. Except for the specimen of high barrier property (the result of gas permeance is less than or equal to  $0.5 \text{cm}^3/(\text{m}^2 \cdot 24 \text{h} \cdot 0.1 \text{MPa})$ ), the measurement of each specimen should not deviate from the mean value by more than  $\pm 10\%$ . The measurement of each specimen of high barrier property should not be greater than  $0.5 \text{cm}^3/(\text{m}^2 \cdot 24 \text{h} \cdot 0.1 \text{MPa})$ .

85

## Method 2 Coulometric analysis method (Coulometric method)

The transmission cell is divided into two parts by the test specimen. Oxygen is purged on one side, and the carrier gas of nitrogen is purged on the other side. The oxygen passing through the specimen is transported by the nitrogen carrier gas into the coulometric analyzer, where chemical reaction occurs to produce electric voltage, which is proportional to the amount of oxygen flowing into the coulometricanalyzer per unit time.

Apparatus and materials An apparatus for determining gas permeance by
 coulometric analysis method mainly consists of the following parts:

Transmission cell Consisting of two parts, the cell should be equipped with thermometric devices and assembled with suitable closures. The test area of the specimens, generally between1-150 cm<sup>2</sup>, should be adapted according to the range of values to be determined.

98 Carrier gas It normally could be nitrogen gas or a nitrogen-hydrogen hybrid gas
 99 containing certain ratio of hydrogen.

100 **Test gas** The purity should not be less than 99.5%.

101 **Coulometric detector (Coulometer)** The detector, sensitive to oxygen, with a 102 constant operation characteristic, could be used to measure the quantity of oxygen 103 transmitted.

Procedure Choose three pieces of the test specimens, which should be of 104 uniform thickness and suitable size, and should be free from wrinkles, creases, 105 pinholes and other defects. Mark the side of each specimen facing the test gas, and 106 condition the specimens at  $23^{\circ}C \pm 2^{\circ}C$  in a desiccator for more than 48 hours. 107 Measure the thickness at least five points of each specimen to the nearest 0.001 mm 108 with a suitable gage, and take the arithmetic mean of the measurements. Place the 109 specimen into the transmission cell, and then perform the test. End the test when the 110 111 output signals of the apparatus are steady for a period of time.

112 The oxygen gas transmission rate  $(O_2GTR)$  could be calculated according to the following equation: 113  $O_2 GTR = \frac{(E_e - E_0) \times Q}{A \times R}$ 114  $O_2$ GTR is the oxygen transmission rate, cm<sup>3</sup>/ (m<sup>2</sup>·24h); Where: 115 E<sub>e</sub> is the observed steady-state voltage, mV; 116  $E_0$  is the zero level voltage before the experiment, mV; 117 A is the area of the specimen,  $m^2$ ; 118 Q is the calibration constant of the apparatus,  $cm^3\Omega/(mV\cdot 24h)$ ; 119 R is the value of load resistance,  $\Omega$ . 120 The oxygen gas permeance  $(P_{0_2})$  could be calculated according to the following 121 equation: 122  $P_{O_2} = \frac{O_2 GTR}{P}$ 123 Where:  $P_{0_2}$  is the oxygen permeance, cm<sup>3</sup>/ (m<sup>2</sup>·24h·0.1MPa); 124  $O_2$ GTR is the oxygen transmission rate, cm<sup>3</sup>/(m<sup>2</sup>·24h); 125 P is the partial pressure of oxygen on the test gas side of the transmission cell, 126 MPa, which is the product of mol fraction of oxygen and total pressure 127 (normally, one atmosphere). The partial pressure of oxygen on the carrier gas 128 129 side is considered to be zero. The oxygen permeability coefficient  $(P_{0_2})$  could be calculated according to the 130 following equation: 131  $P_{O_2}' = P_{O_2} \times D$ 132 Where:  $P'_{0_2}$  is the oxygen permeability coefficient, cm<sup>3</sup>/ (m·24h·0.1Mpa); 133  $P_{O_2}$  is the oxygen permeance, cm³/ (m²·24h·0.1MPa); 134 D is the average thickness of the test specimen, m. 135 Take the arithmetic mean of three specimens as the test result. Except for the 136 specimen of high barrier property (the gas permeance result is less than or equal to 0.5 137  $m^{3}/(m^{2}\cdot 24h\cdot 0.1MPa))$ , the measurement of each specimen should not deviate from the 138 mean value by more than  $\pm 10\%$ . The measurement of each specimen of high barrier 139 property should not be greater than  $0.5 \text{ cm}^3/(\text{m}^2 \cdot 24 \text{h} \cdot 0.1 \text{MPa})$ . 140 141 Note Under the controlled conditions of temperature and humidity, the tester 142 equipped with suitable package test stations could be employed further to determine 143 the oxygen permeance of containers. Perform the test according to the instrument 144 operation manual.

起草单位: 上海市食品药品包装材料测试所联系电话: 021-50798250

参与单位:山东省医疗器械和药品包装检验研究院